



CERTIFICATE FI/40812

Our Ref. HEL-CERT191100722-03



Product Cable trunking/ducting system

Type DUCTEL

Trademark DUCTEL

Certificate Holder MP Bolagen Industri AB
Box 3
SE-57421, Vetlanda, Sweden

Technical information Rated voltage 400 V
Degree of protection IP20 (IP34)
Material AI
See page 2 of this Certificate

The product is certified according to the following standard(s) EN 50085-1:2005 + A1:2013
EN 50085-2-1:2006 + A1:2011
EN 60670-1:2005 + A1:2013
EN 60947-7-2:2009

Validity This certificate is valid until 11 September 2025 provided that the Conditions for FI certification are met. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.

Date of issue 11 September 2020

SGS Fimko Ltd

Signature



Sixten Lökfors
Project Manager



SGS Fimko Ltd

Takomotie 8, FI-00380 Helsinki, Finland
t. +358 9 696 361 www.sgs.fi

Business ID 0978538-5

Member of the SGS Group (SGS SA)



Manufacturer MP Bolagen Industri AB
Box 3
SE-57421, Vetlanda, Sweden

Manufacturing site MP Bolagen Industri AB
Barkvägen 7, Ekenässjön
SE-57491, Vetlanda, Sweden

Directive information The certified product(s) fulfils requirements of mentioned standard(s) which are harmonised under the Low Voltage Directive (2014/35/EU) at the date of issue of the certificate.

Additional information DUCTEL-series includes following parts:

| | | | | |
|-----------------|-----------|-----------|-----------|-----------|
| Trunking | | | | |
| TB 1010-1 | TB 1010-3 | TB 1032-3 | TB 1040-1 | TB 1040-3 |
| TB 1210-3 | TB 1310-1 | TB 1310-3 | TB 1332-3 | TB 1340-1 |
| TB 1340-3 | TB 1710-1 | TB 1710-3 | TB 1740-1 | TB 1740-3 |
| TB 2210-1 | TB 2210-3 | TB 2240-1 | TB 2240-3 | |

| | | |
|----------------------|-------------|---------|
| Corner | TBC-series | |
| Top frame | TBCF-series | |
| End plate | TBP-series | |
| Cover | TB-series | |
| Wall bracket | TBE-series | |
| Adjusting piece | TBE-series | |
| Panel and panel clip | TBE-series | |
| Wall collar | TBO-series | |
| Jointing collar | TBL-series | |
| Jointing piece | TBJ 1 | |
| Sound absorber | XTBO 304 | |
| Sound absorber | XTBO 308 | |
| Mounting box | TBF 1 | IP34 *) |
| Mounting box | TBF 2 | |
| Mounting box | XTBF 1211 | IP34 *) |
| Partition | TDH 1 | |
| Strain relief | TBF 11 | |
| Fitting ring | TBF 12 | |
| Fastening clamp | TBK 1 | |
| Earthing clamp | TBM 1 | |

*) Classification IP34 with relevant socket-outlet IP44

This certificate replaces certificate FI/40481 dated 27 November 2019, due to new testing.

Based on: 277456-1, 283579-1, 288952-2 and 298182-1

Page 2 of 2

This document is issued by the Company under its General Conditions of Service accessible at http://www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SGS Fimko Ltd

Takomotie 8, FI-00380 Helsinki, Finland
t. +358 9 696 361 www.sgs.fi

Business ID 0978538-5



FINAS
Finnish Accreditation Service
S003 (EN ISO/IEC 17065)

Member of the SGS Group (SGS SA)